



Office of the District Fire Officer
Karnataka State Fire and Emergency services
Davanagere Fire station premises
Davanagere Dist-577003.



C.No:20/FACC/SCI/183/DFO/DVG/2026

Date:08/08/2026

TO,

The Head Master
Mandaara Public School,
U Dis No-29140206304
Neelanahalli Village,
Davanagere Tq & Dist.-577566.

Sir,

Sub: Issue of Fire Advisory Compliance Certificate to “Mandaara Education Trust @, Mandaara Public School” situated at Neelanahalli Village, Davanagere Tq & Dist.-577566.

Ref: 1) The District Fire Officer, davanagere Office Fire Safety Recommendation
C.No:20/FAC/SCI/183/DFO/DVG/2026 Date:07/08/2026
2) Your letter dated: 07/08/2026
3) IR : C.No:03/SCI/48/FSTO/DFS/2026 dated:08-08-2026

>>>>><<<<<

With reference to subject cited above, Fire Advisory Certificate was issued vide reference (1) to “Mandaara Education Trust @, Mandaara Public School” situated at Neelanahalli Village, Davanagere Tq & Dist.-577566. With a condition to fulfill the Recommendations and Compliance the same.

With reference cited (2) above, The Head Master of Mandaara Education Trust @, Mandaara Public School” situated at Neelanahalli Village, Davanagere Tq & Dist.-577566. had requested for issue of the **Fire Advisory Compliance Certificate** from our department. In this regard the building was inspected by Fire Station Officer Davanagere on **08/08/2026** and with reference cited (3) above Submitted the report of fulfilled the firefighting systems and found the firefighting systems are in good working condition during inspection and recommended to issue Fire Safety Compliance Certificate.

Under the above Circumstance the Karnataka Fire & Emergency Services Department is issuing the **Mandaara Education Trust @, Mandaara Public School**” situated at Neelanahalli Village, Davanagere Tq & Dist.-577566. subject to proper maintenance of firefighting installations in good working condition and impart 40% of employees should be trained in basic firefighting within 90 days from the date of issue of this Certificate.

This fire Advisory compliance certificate is valid till dated 07/08/2027 and it is renewable without Fail.

Yours Faithfully.


District Fire Officer
Karnataka Fire & Emergency Service
Davanagere District



Office of the District Fire Officer,
Karnataka State Fire and Emergency services,
Davanagere Fire station premises,
Davanagere Dist-577003.



C.No:20/FAC/SCI/183/DFO/DVG/2026

Date:07/08/2026

TO,

The Head Master
Mandaara Public School,
U Dise No-29140206304
Neelanahalli Village,
Davanagere Tq & Dist.-577566.

Sir,

Sub: Issue of "**Fire Advisory Certificate**" to "**Mandaara Education Trust @, Mandaara Public School**" situated at Neelanahalli Village, Davanagere Tq & Dist.-577566.

Ref: 1. your letter dated 06/08/2026
2. GBC(2)044/2020-21 dated:21-06-2022
3. GBC (2) 2100/2025 dated:03-02-2026
4. C.No:03/SCI/48/FSTO/DFS/2026 dated:06-08-2026

With reference to the subject above, the premises of "**Mandaara Education Trust @, Mandaara Public School**" situated at Neelanahalli Village, Davanagere Tq & Dist.-577566..was inspected by Fire Station Officer Davanagere on **06/08/2026** with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

ANNEXURE-B**Group B, Educational Buildings.**

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory).

A. Details of the building / premises :-

SINo.	Details	:	Observation
01.	Name and Address of the Applicant.	:	The Head Master Mandaara Education Trust @, Mandaara Public School, U Dise No-29140206304 Neelanahalli Village, Davanagere Tq & Dist.-577566.
02.	Name and Address of the premises.	:	Mandaara Public School, U Dise No-29140206304 Neelanahalli Village, Davanagere Tq & Dist.-577566.



03.	Name & address of the building owner	:	The Head Master Mandaara Education Trust @, Mandaara Public School, U Dise No-29140206304 Neelanahalli Village, Davanagere Tq & Dist.-577566.
04.	Number of buildings	:	Only One Building
05.	Number Of Floors	:	Ground and One Upper Floor
06.	Floor-wise Occupancy details	:	
	Ground floor	:	10 Class rooms, Administration room, Office room, Lab room, HM room and Toilets.
	First floor	:	06 Class rooms, Library room, staff room, 03 Lab rooms and Toilets.
07	Height of the building	:	09.20 mtrs
08	Site Area	:	9810.00 Sq mtrs
09	Built up area	:	
	Ground floor	:	2587.00 Sq. mtrs.
	First floor	:	1922.00 Sq. mtrs.
	Total built-up area	:	4509.00 Sqmtrs
10.	<u>Surrounding properties:-</u>		
	North (Front)	:	Playground thereafter 05.00 mtr wide approach road.
	South (Rear)	:	Agricultural land
	East (Side)	:	Agricultural land
	West (side)	:	Agricultural land
11	<u>Open space all around the building:-</u>		
	North (Front)	:	12.00 mtrs
	South (Rear)	:	06.50 mtrs
	East (Side)	:	04.00 mtrs
	West (side)	:	05.00 mtrs
	Allowed setbacks (open space) should be maintained free from further obstruction / construction		



B. On inspection of this Educational Building, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)			Recommendations (04)
01.	Accessibility to the Premises	The premises is accessible from 05.00 mtrs wide approach road, located on Northern Side & The Road is hardened to carry the weight of 45,000 kgs.			Adequate
02.	Number of entrances	Provided 02 Entry/Exit with adequate measure of 06.10 mtr width. & another one is 01.50 mtr width			Complied
03	No. Of Staircases Available	No. of staircases.	03 no's		
			A	B	C
		Width of staircases	01.80. Mtrs.	01.80. Mtrs.	01.20. Mtrs.
		Width of treads	27Cm's	27Cm's	27Cm's
		Height of risers	14Cm's.	14Cm's.	13Cm's.
		No's. of riser per flight	11 No's.	11 No's.	10 No's.
		Height of the Handrails	00.95 Mtr.	00.95 Mtr.	01.05 Mtr.
04.	Portable extinguishers	Not Provided			Not Complied A. One CO2 type fire extinguisher, of 4.5 kgs capacity should be provided near electrical panel board & electrical room. B. One ABC type fire extinguisher of 06 kgs capacity should be located as to be available within 100 Sq. mtrs Of the building. (All the Extinguishers Suggested above should be with BIS markings and should be located at an easily accessible position without Obstructing the normal passage and maintained periodically)



05.	Escape routes	Not Provided	Not Complied Directions in which the students and faculty should have to move in the event of any emergency have to be indicated in the corridor/passage on ground floor as a guide during evacuation. These should be in luminous paint.
06.	Fire order (Fire safety plans)	Provided Notice boards indicating the details of action to be taken in case of any emergency with telephone numbers of Davanagere Fire station i.e. 08192-258101, & 112,101 and nearby ambulance service have been displayed near staircase landing at ground floor.	Complied
07	No smoking board	Not Displayed	Not Complied COTPA Sec-4 direction No Smoking area smoking here is an offence board are written in English & Kannada both language shall be prominently displayed at inside the entry / exit of the ground floor.
08.	Fire Siren	Not Installed	Not Complied A Fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.
09	Nominate one Fire Nodal Officer	Not Nominated	Not Complied A fire nodal officer shall be nominated either from teaching or non teaching staff.
10	Training in Fire fighting	Not imparted	Not complied At-least 40% of Teaching and non Teaching staff should be got trained in basic fire fighting at R.A. Mundkur Fire and Emergency Services Academy, Bannerughatta road, Bangalore or Regional Training Centre.



11

Fire precautionary measures :-

- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
- B. Accumulation of combustible waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction.
- D. Liquefied petroleum gas should not be stored in the building.
- E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to outside.

As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing "**Fire Advisory Certificate**" to "**Mandaara Education Trust @, Mandaara Public School**" situated at Neelanahalli Village, Davanagere Tq & Dist.-577566.

Subject to condition and compliance of the above recommendations in coloumn-4 of series-B within 3 months and compliance to the undersigned.

❖ All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of fire and life safety will have to be complied with mandatory

Yours faithfully.


District Fire Officer
Karnataka Fire & Emergency Service
Davanagere District